



WELL TEST ANALYSIS

Data Set: C:\...\20.10.P6-S1.AQT

Date: 02/22/07

Time: 13:52:04

AQUIFER DATA

Saturated Thickness: 31.09 m

WELL DATA

Pumping Wells

Observation Wells

Well Name	X (m)	Y (m)	Well Name	X (m)	Y (m)
PW 3	399594.063	4072292.635	o P6 S1	399491.565	4072203.912

SOLUTION

Aquifer Model: Unconfined

Solution Method: Neuman

T = 168.3 m<sup>2</sup>/day

S = 0.002396

Sy = 0.2342

β = 5.92